

**OREGN**

Oregon  
Convention  
Center

Living  
Our

**OG**

# **RIGGING RULES AND REGULATIONS**

July 2024 - June 2025

## **WE ARE A CENTER IN MOTION.**

Defined by you and what you can accomplish inside our walls.

We don't decide the future.

We provide a place where you can.

Where you can

Join. Change. Dismantle. Engage.

*Cherish, Love, Uphold, Refute, Challenge, Galvanize and Improvise -*  
until you figure out what will come next.

## **THIS IS A PLACE OF ACTION.**

There are no nos, no if onlys, no maybes.

There is only right now.

Ready? Go.

**OREGON**

Oregon  
Convention  
Center



Rigging Definitions	4
Sign, Banner, and Ground Supported Rigging	4
Aerial Rigging	5
Prohibited	5
Contractor Guidelines	5
Certified Rigger	6
Certified Rigger Requirements	6
Frequent Questions	7

## RIGGING DEFINITIONS

### RIGGING

Rigging is defined as the attachment of objects to the ceiling steel, air wall tracks, ballroom points, or the suspension of objects from any portion of the physical building.

### SIGN RIGGING

Sign rigging as used in this document refers to the overhead suspension of objects under 20 lbs.

### BANNER RIGGING

Banner rigging as used in this document refers to the overhead suspension of objects over 20 lbs. and under 100 lbs.

### GROUND SUPPORTED RIGGING

Ground supported rigging is defined as the attachment of objects to a load-bearing apparatus such as crank-up, electric, hydraulic, mechanized, self-climbing, manually built self-supporting truss systems, hoisting towers, single mast sound, lighting trees, or other similar “stick” rigging device.

### AERIAL RIGGING

Aerial rigging as used in this document refers to the overhead suspension of objects over 100 lbs. and requires the use of ON Site Audio Visual, OCC’s preferred audiovisual provider, who is the exclusive provider of rigging labor services. This also includes chain motor rental.

CAD drawings of all spaces are available at [oregoncc.org/en/rigging](http://oregoncc.org/en/rigging).



### SIGN RIGGING

Non-motorized banners, aisle signs, aluminum framed hanging signs and other expo elements that are under 20 lbs. do not require a plot review. Exceptions to the 20 lbs. rule may be made for banners hanging

directly on a wall with approval of the OCC. All expo elements are required to be rigged with hardware that is rated for overhead lifting.

### BANNER RIGGING

Non-motorized banners, aisle signs, aluminum framed hanging signs, and other expo elements that are over 20 lbs. and under 100 lbs. do require a plot review. A plot must be submitted 30 days prior to the event move-in date for approval. All expo elements are required to be rigged with hardware that is rated for overhead lifting.

### GROUND SUPPORTED RIGGING

Ground supported rigging is defined as the attachment of objects to a load-bearing apparatus such as crank-up, electric, hydraulic, mechanized, self-climbing, manually built self-supporting truss systems, hoisting towers, single mast sound, lighting trees, or other similar “stick” rigging device.

Floor supported structures over 20’ must be properly secured, meet all safety guidelines and are subject to onsite review by OCC. Free-standing items may not obstruct mandatory exit aisles, doorways, exit lights, AED devices, fire alarm pull boxes, fire hose cabinets, or fire extinguishers. Support legs must be positioned, marked, or otherwise protected to avoid trip hazards. Items may not block necessary service access into the room. Certified riggers may be required for ground supported rigging.

Ground/floor-based rigging/truss that exceeds 16’ in height must have an overhead support system that connects into the facility rig points unless there is an engineer stamped drawing indicating that this is not necessary.

All ground supported installations with a trim height greater than 12 feet must be inspected and approved.

## AERIAL RIGGING

Please submit all rigging plots for quoting to ON Site Audio Visual, OCC's exclusive provider of rigging labor services. This also includes chain motor rental.

### ALLOWED RIGGING POINTS AND LOAD LIMITS

#### Exhibit Halls A/A1/B/C

T1 Steel Beams: 4,000 lbs. per panel point.  
Open Web Joist: 500 lbs. at a panel point, between T1 steel.

#### Exhibit Halls D/E

T1 Steel Beams: 2,000 lbs. per panel point.  
Open Web Joist: 1,500 lbs. at a panel point, per span between T1 steel.

#### Oregon and Portland Ballrooms

Threaded points: 1,000 lbs. per point.

#### Meeting Rooms and Lobbies

There are no weight-bearing points in these areas.

### TRIM HEIGHTS

#### Exhibit Halls

T1 Steel Beams: between 32' - 34'  
Open Web Joist: between 43' - 45'  
Light Squares: 30'

#### Portland Ballroom

Ceiling: 29'  
Soffit: 28'

#### Oregon Ballroom

The Oregon Ballroom has special conditions. The ceiling is constructed from floating three-dimensional discs hung at heights between 23' - 25' to create the effect of a tree canopy. The rigging points are recessed between the discs. The cost of any damage to the canopy will be billed back to the licensee.

Ceiling - 25'  
Soffit - 23'

## PROHIBITED

- No rigging from any structure other than open web joist and T1 beams and threaded points.
- No bridling allowed from open web joist.
- No live loads on open web joist.
- No bridling allowed on threaded points.
- No live loads on threaded points.
- No hanging from hot rails in the exhibit halls.
- No hanging from light squares in exhibit halls.
- No hanging from lighting fixtures in ballrooms.
- No use of trick-line and other non-rated hardware.
- No non-rated synthetic cordage.
- No hanging signs with solid fabric underside.

## CONTRACTOR GUIDELINES

All rigging plots must be submitted through an OCC event manager for review and approval no less than 30 days prior to the event move-in date.

All plots must include an individual per point weight load calculation.

Rigging plots for the exhibit halls must display the following layers:

- Walls
- T1 Steel Beams
- OWJ Beams
- Threaded points
- Building HVAC
- Building Cable Trays

Rigging is ONLY allowed from the top or bottom of the open web joist at the panel point.

A protective wrap must be used around beams.

All rigging hardware must have the manufacturer's stamp and meet OSHA and ANSI standards.

The first review prior to 30 days out will be at no cost. Each additional review will incur a fee.

No rigging will be allowed without approval. A rigging inspection fee may be applied for on-site inspection.

Contractors are expected to abide by all the rules and regulations of OCC.

During the period of occupancy, the Licensee is ultimately responsible for any damage that occurs due to the hanging or attachment of items to the facility or to facility-owned equipment by any exhibitor, contractor, representative or agent.

## **CERTIFIED RIGGER**

The Entertainment Technician Certification Program (ETCP) is an industry-wide program created by the Entertainment Services and Technology Association (ESTA). ETCP certification focuses on installation activities that directly affect the health and safety of crews, performers, and audiences and requires compliance with OSHA and other laws. ETCP certified riggers have met experience and training eligibility requirements and passed rigorous testing to ensure proper installation of rigging to temporarily suspend objects from overhead structures in any environment.

More information on ETCP certification requirements can be found at [etcp.esta.org](http://etcp.esta.org).

## **CERTIFIED RIGGER REQUIREMENTS**

Any rigging at the Center, either ground supported or aerial, may be required to be installed by ETCP certified riggers at OCC's behest. An ETCP certified rigger will be identified by ON Site Audio Visual as the rigging supervisor for the installation. This

rigging supervisor must submit inspection and approval documents assuring that all rigging for the event, whether aerial or ground supported, is installed in a safe and effective manner, meeting all requirements, policies and procedures of the OCC.

## QUESTION 1

**Am I required to use an ON Site Audio Visual technician to assemble my truss system or for the attachment of gear to the truss system?**

All qualified audiovisual contractors may assemble truss systems as well as attach lighting, sound, and projection equipment to truss systems. An ON Site Audio Visual technician is always required to control (raise or lower) chain motors.

## QUESTION 2

**Am I required to use ON Site Audio Visual for ground supported applications in the ballroom spaces?**

All qualified audiovisual contractors may assemble and construct ground supported systems. Please also review Ground Supported Rigging information on page 4.

Living  
Our

OG